

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

PV 50639022 0001

Berichtsnummer Report No.:

CN24M57I 002

Genehmigungsinhaber License Holder:

ZES Solar Enerji Tedarik ve Ticaret A.Ş
Esentepe mak Büyükdere cad no:199 Şişli/İstanbul
34360 İstanbul
Türkiye

Fertigungsstätte Manufacturing Site:

040-0001640463

Prüfzeichen Test Mark:

Geprüft nach Tested according to:

IEC 61215-1:2021
IEC 61215-1-1:2021
IEC 61215-2:2021
IEC 61730-1:2023
IEC 61730-2:2023
EN IEC 61215-1:2021
EN IEC 61215-1-1:2021
EN IEC 61215-2:2021
EN IEC 61730-1:2018
EN IEC 61730-2:2018

Geräteidentifikation
Product Identification
Produkt:

PV Module

Product:
Modell:

Modelle sind auf nächste(r) Seite(n) gelistet

Type:

Type designation(s) are listed on the next page(s)

Technische Daten:

Class II acc. to IEC 61140

Technical Data:

For other ratings, refer to the test report

Gültig bis:

2029-04-22

Date of expiry:
Gültig ab:

2024-07-19

Valid from:
Ausstellungsdatum:

2024-07-19

Date of issue:
Zertifizierungsstelle:
Certification body:


Dipl.-Ing. (FH) Tim Kirschner

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com

 **TÜVRheinland®**
Precisely Right.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

PV 50639022 0001

Berichtsnummer *Report No.:*

CN24M57I 002

Produkt *Product:* PV Module**Modell** *Type:***Bezeichnung** *Designation:*

Max. System Voltage: up to 1500 VDC

ZES-XXX-HC182TC-01 (xxx = 585-600, in steps of 5,
144 cells, Pmax@BNPI=650-665)ZES-XXX-HC182TC1-01 (xxx = 490-500, in steps of 5,
120 cells, Pmax@BNPI=550-560)

xxx represents output power in Wp

Remarks:

Fire Rating: Class A (according to UL 790)

Design Load / Safety Factors: 3600 Pa / 1.5 (downward)
1600 Pa / 1.5 (upward)**Conditions:**

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

